

CERTIFIED/LISTED PRODUCTS

NSF/ANSI STANDARD 385 Disinfection Mechanics

Sect. 6 – Chlorine Disinfection Devices:

Norweco, Inc.
220 Republic Street
Norwalk, OH 44857-1156
United States
419-668-4471
www.norweco.com

Facility: Norwalk, OH

Model	Rated Capacity (GPD)	Classification	Listing Date
Bio-Dynamic LF Series Tablet Feeders***		Chlorine Disinfection Device	
Model LF 500	200 – 1500		10 Feb 2021
Model LF 1000	200 – 1500		18 Nov 2020
Model LF 1500	200 – 1500		10 Feb 2021
Model LF 2000	200 – 1500		10 Feb 2021
Model LF 3000	200 – 1500		10 Feb 2021
Model LF 4600	200 – 1500		10 Feb 2021
Model LF 4800	200 – 1500		10 Feb 2021

*Certified with the use of Bio-Sanitizer or Blue Crystal Disinfecting Tablets.

**Although certain model disinfection devices may be capable of disinfecting flows greater than 1500 GPD, the scope of the Standard does not apply to treatment capacities outside the range of 200 – 1500 GPD.

Sect. 7 - Ultraviolet Disinfection Devices:

No Listed Products for this Category

Sect. 8 - Ozone Disinfection Devices:

No Listed Products for this Category



High Standards • Integrity • Technical Expertise

